

Umatilla School District Radon Retest Results

Room	March 22	April 5	Average	Recommendations
101	4.4	2.1	3.25	Long Term Test
101B	4.5	1.8	3.15	Long Term Test
11	5.1	5.1	5.1	Mitigation
112	8.0	1.9	4.95	Mitigation
16	4.2	4.9	4.55	Mitigation
Weight Room	4.0	3.9	3.95	Mitigation